

Figure: 25 TAC §265.193(c)

<b>Required Chemical Levels</b>			
<b>Disinfectant Level</b>	<b>Minimum</b>	<b>Ideal</b>	<b>Maximum</b>
Pool Free Available Chlorine	1.0 ppm	2.0 – 3.0 ppm	8.0 ppm
Spa Free Available Chlorine	2.0 ppm	3.0 ppm	8.0 ppm
Pool Bromine	3.0 ppm	4.0 – 6.0 ppm	10.0 ppm
Spa Bromine	4.0 ppm	5.0 ppm	10.0 ppm
Combined Chlorine	None	None	0.4 ppm
pH	Not less than 7.0	7.2 – 7.6	7.8
Cyanuric Acid	None	30 – 50 ppm	100 ppm
ORP	600 mV	650 – 750 mV	900 mV
Alkalinity	60 ppm	60 ppm – 180 ppm	>180 ppm
Calcium Hardness in Pools	150 ppm	>150 – 400 ppm	1000 ppm
Calcium Hardness in Spas	100 ppm	150 – 400 ppm	800 ppm